

## TESTED RESULTS

### Northington Road, Itchen Abbas

Determinands	Unit	Base Value	2025											
			Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Total Nitrogen	mg/l	70.90	29.80	28.60	18.80	6.50	19.80	16.50	15.10	12.00	31.90*	37.70*	27.90*	20.20
Total Phosphate	mg/l	9.70	7.43	6.62	8.48	10.20	10.40	9.92	8.83	8.31	9.05	8.10	9.02	8.48

\* These samples have been analysed for Nitrogen, Total as N outside recommended stability times. It is therefore possible that the results provided may be compromised

### The Goodens, Chariton

Determinands	Unit	Base Value	2025											
			Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Total Nitrogen	mg/l	94.30	9.10	2.60	9.20	2.30	-	4.40	7.30	7.60	24.60*	43.70*	2.10*	24.60
Total Phosphate	mg/l	11.60	3.68	0.41	8.08	0.87	-	1.35	9.23	2.26	8.69	2.97	1.46	10.50

\* These samples have been analysed for Nitrogen, Total as N outside recommended stability times. It is therefore possible that the results provided may be compromised

### Itchen View, Itchen Abbas

Determinands	Unit	Base Value	2025											
			Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Total Nitrogen	mg/l	70.90	-	-	-	-	-	-	-	-	50.70*	62.60*	57.10*	51.80
Total Phosphate	mg/l	9.70	-	-	-	-	-	-	-	-	10.60	11.70	12.50	10.30

\* These samples have been analysed for Nitrogen, Total as N outside recommended stability times. It is therefore possible that the results provided may be compromised